



SOUTH DELHI MUNICIPAL CORPORATION
PUBLIC HEALTH DEPARTMENT : NAJAFGARH ZONE
DHANSA STAND, NAJAFGARH, NEW DELHI 110043

No: DHO/NGZ/2020/ 3739

Dated 13/2/2020

1. Name of the School... Shree Ram World School
... run by Mata Phoolan Wankh Educational Society
2. School Address... Sector 10, Dwarka New Delhi
3. No. of Shifts :... One Timings... 8:00 am to 2:30 pm
1. No. of Students: Boys... 751 Girls... 530 Total... 1281
2. No. of Staffs: Male... 11 Female... 71 Total... 82

Details of Accommodations present in the school

- Floor area/ space in the Classroom sufficient/ insufficient... Sufficient
- Classes are well lighted/ ill lighted... Well lighted
- Classrooms are well ventilated/ ill ventilated... Well ventilated
- Classes are kept / not kept neat and clean... Neat & clean
- Classrooms/Building require / do not require white wash etc... Not required
- Drinking water is wholesome / not wholesome... Wholesome
- Latrine arrangement is sanitary /insanitary... Sanitary from health point of view

No. of toilets seats for students

- One latrine-cum-urinal is required for 25 female students, so total is... Sufficient
- One latrine for 40 male students is required so total is... Sufficient
- Separate toilet arrangement for staff yes / no... Yes exist Separati for staff.
- The overall facilities good/adequate/inadequate... Adequate from health point of view & valid upto one year from issuance date

If Building Department or any other Govt. agency takes actions against w/a constructions or any dispute, then the Health Certificate will be stand cancelled/ revoked without any further intimation in this regard.

Shree Ram World School
Sector 10, Dwarka New Delhi

13/2/2020
Dy. Health Officer
Najafgarh Zone
S.D.M.C. Najafgarh, Zone

Sharda Arya

SHARDA RYA
Manager
Shree Ram World School
Sec.-10, Dwarka, New Delhi-110075

DELHI JAL BOARD
(GOVT OF NCT OF DELHI)
ZONAL LABORATORY SOUTH - WEST WATER WORKS "DWARKA"

B8

Chief Water An.
D.J.B.
Diary No. 1693
Date... 19/6/19

Analysis of water samples collected from Shree Ram World School C/O Ms Sudhakar Sadangi, Head of School, letter no SRWS/Admn/water /2019 Dated 4.6.19 vide challan No.60 Dated 6.6.19

Date: 15.6.19

S.NO.	PARTICULARS	UNITS	
1.	Date of collection		11.6.19
2.	Colour	PtCo	Clear
3.	Turbidity (1-5)	NTU	1.2
4.	pH Value (6.5 - 8.5)		7.6
5.	Conductivity	$\mu\text{mho}/\text{cm}^2$	205
6.	T.D.S. (500-2000)	Mg/L	133
7.	Phenolphthalein Alkalinity	Mg/L	Nil
8.	Total Alkalinity as CaCO_3 (200-600)	Mg/L	64
9.	Total Hardness as CaCO_3	Mg/L	78
10.	Carbonate Hardness	Mg/L	64
11.	Non-Carbonate Hardness	Mg/L	14
12.	Calcium Hardness as Ca (75-200)	Mg/L	22.4
13.	Mg Hardness as Mg (30-100)	Mg/L	5.28
14.	Ammonical Nitrogen (0.5)	Mg/L	Nil
15.	Nitrite as N	Mg/L	Nil
16.	Nitrate as NO_3 (45)	Mg/L	3.2
17.	Chloride as Cl (250-1000)	Mg/L	14.0
18.	Sulphate as SO_4 (200-400)	Mg/L	28
19.	Iron as Fe (0.3)	Mg/L	0.12
20.	Fluoride as F (1.0-1.5)	Mg/L	0.26
21.	Phosphate	Mg/L	Nil
22.	Residual Chlorine	Mg/l	0.5
	Bacteriological Analysis		
	MPN/100ml		0

REMARKS: On the basis of parameters tested above sample conforms BIS-10500 and found fit for drinking purpose.

Alu
15/6/19

ASSTT. CHEMIST

CHEMIST

Sharda
ACWA
DELHI JAL BOARD
Govt. of N.C.T. Delhi
Quality Control Laboratory
Water Works, Nareloi, Delhi-110075

Sharda Arya

SHARDAARYA

Manager

Shree Ram World School

Sec-10 Dwarka, New Delhi 110075

DELHI JAL BOARD: GOVT. OF NCT OF DELHI
OFFICE OF THE EXECUTIVE ENGINEER (RWH/GWC)
ROOM NO. 209, VARUNALAYA PHASE-I
KAROL BAGH, NEW DELHI - 110005
23558264

No./DJB/EE(RWH/GWC)/2018/5125

DATED: 18/9/18

To,


Head of School
Shree Ram World School
Sec-10, Dwarka, New Delhi-75


Subject:- Regarding adequacy of rain water harvesting system at Shree Ram World School, Sec-10, Dwarka, New Delhi-75.

Sir,

Please refer to your letter dated 18/09/2018 in which you have informed that rain water harvesting system has been installed at your above said premises as per the design issued by DJB vide letter No. DJB/EE(RWH/GWC)/2018/4978 dated 14.09.2018. The said RWH structure is sufficient and adequate to harvest the catchment area of your school.

You are requested to keep the existing RWH system neat & clean & maintain the same periodically.


EE (RWH/GWC)
EE (G W CELL)
DELHI JAL BOARD
VARUNALAYA CHOWAN,
DELHI - 110005


SHARDAARYA
Manager
Shree Ram World School
Sec.-10, Dwarka, New Delhi-110075